



N·C·S·D

Northstar Fire Department

Northstar Community Services District

910 Northstar Drive, Northstar, CA 96161

P: 530.562.1212 • F: 530.562.0702 • www.northstarcسد.org

Board of Directors

WARREN "CHIP" BROWN

JEANN GREEN

NANCY P. IVES

DARRELL SMITH

CATHY STEWART, PRESIDENT

Fire Chief

SEAN BAILEY

Stand-by Power Generator Installation:

1. Northstar Fire Department (NFD) requires the installation to be a part of the Placer County permit process. If there is a new permit number, please provide it.
2. Provide a site plan showing the location of the generator and service disconnect. Placement of disconnect accessible in Winter?
3. Provide cut sheets for the generator.
4. Warning Placard required at the house's main electrical panel shut off. Wording to convey the following: "Warning, Stand-by Power generator on-premise will activate when building power is terminated. Use generator disconnect located at...."
5. Generator, gas line, and power connections per Placer County Building Department, 2013 CBC, Mechanical codes, and manufacturer's specifications.

Feel free to contact this office for additional information or clarification of this e-mail.

Sincerely,

Jason Gibeaut

Community Risk Reduction Div. Chief

Northstar Fire Department

910 Northstar drive

(530) 562-1212 x 1

(530) 562-0702 (fax)

jgibeaut@northstarcسد.org

www.northstarcسد.org