

RESIDENCE (BUILDING)



- NOTES:
- A. GAS SHUT-OFF VALVE LOCATED AT STUB OUT.
 - B. TIMER DEVICE TO REGULATE MAXIMUM OPERATING TIME TO (3) THREE HOURS.
 - C. (10) TEN FEET VERTICAL & HORIZONTAL CLEARANCE TO ALL COMBUSTIBLES MEASURED FROM CENTER OF THE FLAME RING.
 - D. GAS SHUT-OFF VALVE ACCESSIBLE AT FIRE PIT.
 - E. (2) TWO FEET MAXIMUM FLAME HEIGHT.
 - F. ALL PARTS/ASSEMBLIES TO BE U.L. OR ASME LISTED.
 - G. SUBMIT SITE PLAN SHOWING LOCATION AND DESIGN.
 - H. PROVIDE CUT SHEETS FOR FIRE PIT SYSTEM.
 - I. SURFACE SUPPORTING FIRE PIT SYSTEM SHALL BE NON-COMBUSTIBLE.

NORTHSTAR COMMUNITY SERVICES DISTRICT
FIRE DEPARTMENT STANDARD SPECIFICATION
RESIDENTIAL FIRE PIT DETAIL

REVISIONS		DATE	BY	APPR'D	DATE	BY	APPR'D
		10/13	EDM	MS			
		10/18	EDM	MS			
		10/24	EDM	MS			

DRAWN BY:	EDM
DATE:	10/16/13
APPROVED BY:	MS
SCALE:	N.T.S.
SHEET:	