

Violation	Corrected	Description
		A. Clear all combustible ground fuels within 5' of a structure. NCSD 35-19 § 4(b)(1)
X		B. Remove all flammable vegetation within 10' of a structure. NCSD 35-19 § 4(b)(5)
		C. Maintain a layer of pine needle/forest duff depth of 1" to a maximum of 2". NCSD 35-19 § 4(b)(2)
		D. Remove any tree limbs within 10' horizontally or vertically from structure. NCSD 35-19 § 4(b)(3)
		E. Prune lower branches of trees to a height of 6' to 15' (or 1/3 tree height for trees under 18'). NCSD 35-19 § 4(b)(4)
		F. Remove all suppressed trees acting as ladder fuels. NCSD 35-19 § 4(b)(11)
		G. Remove all branches within 10' of chimney or stovepipe outlet. PRC § 4291(a)(4) and 14 CCR § 1299.03(a)(2)
		H. Remove leaves, needles or other vegetation on roofs, gutters, decks, porches, stairways. PRC § 4291(a)(6)&14 and 14 CCR § 1299.03(a)(1)
		I. Remove all dead and dying trees, branches, & shrubs or other plants adjacent to or overhanging buildings. PRC § 4291(a)(5)&14, 14 CCR § 1299.03(a)(2) and NCSD 35-19 § 4(b)(7)
		J. Remove all dead and dying grass, plants, shrubs, trees, branches, leaves, weeds & needles. 14 CCR § 1299.03(a)(1)
		K. Remove or separate live flammable ground cover & shrubs. PRC § 4291(a)(4), BOF General Guidelines Item 1 and NCSD 35-19 4(b)(6)
		L. Remove flammable vegetation & items that could catch fire adjacent to or below combustible decks/balconies/stairways. PRC § 4291(a)(3)
		M. Relocate firewood piles at least 30' from any structure or cover with fire resistive materials (tarps). NCSD 35-19 § 4(b)(10)
		N. Cut annual grasses & forbs to a maximum of 4 inches in height. 14 CCR § 1299.03(b)(2)(B)
		O. Remove fuels in accordance with fuel separation or CTC guidelines. NCSD 35-19 § 4(b)(7)
		P. All firewood piles must have a minimum of 10 ft clearance down to bare mineral soil. 14 CCR § 1299.03(b)(2) and NCSD 35-19 § 4(b)(10)
		Q. Dead & dying woody surface fuels & aerial fuels shall be removed. 14 CCR § 1299.03(b)(2)(A)
		R. Logs or stumps embedded in the soil must be removed or isolated from other vegetation. BOF General Guidelines Item 3
		S. Outbuildings & liquid propane gas storage tanks shall have 10' of clearance to bare mineral soil and no flammable vegetation for an additional 10'. 14 CCR § 1299.03(c)(1)
		T. Address numbers shall be displayed in contrasting colors (6 inches minimum size) & readable from the street or access road. NCSD 36-19
		U. Equipment chimney or stovepipe will have metal screens with openings between 3/8" & 1/2". 2019 CBC § 2113.9.2
		V. All highly flammable vegetation and ground fuels must be kept at a distance no less than 3 feet from all ground-level transformers and other utility boxes which may cause a spark. NCSD 35-19 § 4(b)(9)

